



Certificate of Compliance

Certificate Number: LR 103378-1

Revision:

Date Issued: December 21, 1995

Issued To: SUGO INC.
190 Montrose W. Ave.
Akron, OH 44321
USA
Attention: Mr. Jay K. Falz

The products listed below are eligible to bear the CSA Mark.

**NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*

Issued By: G. Lipka, C.E.T.
Toronto, ON Canada

Signature

CLASS

3231 02 - SWITCHES - Automatic - Pressure Type
3231 82 - SWITCHES - Automatic - Pressure Type - CERTIFIED TO U.S. STANDARDS

PRODUCTS

Pressure switches, spst, NC or NO contacts, Models 0163, 0166, 0167, 0168 and 0169, open type, with suffixes, max rating 100VA, 42V (120V ac max).

Pressure switches, spdt, open type, with suffixes, Models 0170, 0171 and 0181 rated 4A, 42V ac max; Models 0190 and 0191 rated 50mA, 24V ac max; Models 0180, 0184, 0185, 0186 and 0187 rated 4A, 250V ac.

APPLICABLE REQUIREMENTS

GAN/GSA-C22.2 No.	14-95	- Industrial Control Equipment
UL Std No.	508	- Industrial Control Equipment
UL Std No.	157	- Gaskets and Seals

* The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.