

3076039

https://www.phoenixcontact.com/us/products/3076039

Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.



Installation ground terminal block, Assembly instruction:

In order to securely fix the neutral busbar in place, support brackets must be placed at the beginning and end of each terminal strip as well as every 20 cm on longer terminal strips. The corresponding support brackets can be found at phoenixcontact.com/products, nom. voltage: 400 V, nominal current: 38 A, Screw connection, Rated cross section: 6 mm², cross section: 0.2 mm² - 10 mm², mounting type: NS 35/7,5, NS 35/15, color: gray

Your advantages

- The asymmetrical arrangement of the terminal blocks on the DIN rail enables the neutral busbar to be routed past the terminal blocks
- · The installation terminal block features a particularly low-profile design and is suitable for wiring in flat installation distributors

Commercial data

Item number	3076039
Packing unit	50 pc
Minimum order quantity	50 pc
Sales key	BE01
Product key	BE1153
Catalog page	Page 180 (C-1-2019)
GTIN	4046356817615
Weight per piece (including packing)	36.42 g
Weight per piece (excluding packing)	36.42 g
Customs tariff number	85369010
Country of origin	PL



3076039

https://www.phoenixcontact.com/us/products/3076039

Technical data

Notes

General	Assembly instruction: In order to securely fix the neutral busbar in place, support brackets must be placed at the beginning and end of each terminal strip as well as every 20 cm on longer terminal strips. The corresponding support brackets can be found at phoenixcontact.com/products
---------	--

Product properties

Product type	Installation terminal block
Number of connections	4
Number of rows	3
Potentials	2
Data management status	

Article revision	02
Insulation characteristics	
Overvoltage category	III

3

Electrical properties

Degree of pollution

Rated surge voltage	6 kV
Maximum power dissipation for nominal condition	1.31 W
Current carrying capacity of the neutral busbar	140 A

Connection data

Grounding foot	Yes
Number of connections per level	2
Nominal cross section	6 mm²

Level 1

Screw thread	M3
Note	Please observe the current carrying capacity of the DIN rails.
Tightening torque	0.5 0.6 Nm
Stripping length	9 mm
Internal cylindrical gage	A5
Conductor cross section rigid	0.2 mm² 10 mm²
Cross section AWG	24 8 (converted acc. to IEC)
Conductor cross section flexible	0.2 mm² 10 mm²
Conductor cross section, flexible [AWG]	24 8 (converted acc. to IEC)
Conductor cross-section flexible (ferrule without plastic sleeve)	0.5 mm² 6 mm²
Flexible conductor cross section (ferrule with plastic sleeve)	0.25 mm² 4 mm²
Nominal current	38 A (with 6 mm² conductor cross section)



3076039

https://www.phoenixcontact.com/us/products/3076039

Maximum load current	47 A (with 10 mm² conductor cross section)
Nominal voltage	400 V (phase conductor/phase conductor)
	250 V (phase conductor/PE)
	250 V (phase conductor/N)
Nominal cross section	6 mm²

Di

Width	8.2 mm
End cover width	2.2 mm
Height	95 mm
Depth on NS 35/7,5	51.5 mm
Depth on NS 35/15	59 mm

Material specifications

Color	gray (RAL 7042)
Flammability rating according to UL 94	V0
Insulating material group	I
Insulating material	PA
Static insulating material application in cold	-60 °C
Relative insulation material temperature index (Elec., UL 746 B)	130 °C
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R26	HL 1 - HL 3
Surface flammability NFPA 130 (ASTM E 162)	passed
Specific optical density of smoke NFPA 130 (ASTM E 662)	passed
Smoke gas toxicity NFPA 130 (SMP 800C)	passed

Electrical tests

Surge voltage test

Test voltage setpoint	4.8 kV
Result	Test passed

Temperature-rise test

Requirement temperature-rise test	Increase in temperature ≤ 45 K
Result	Test passed
Short-time withstand current 6 mm²	0.72 kA
Short-time withstand current 10 mm²	1.2 kA
Result	Test passed

Power-frequency withstand voltage

rower-frequency withstand voitage	
Test voltage setpoint	1.5 kV
Result	Test passed

Mechanical properties



3076039

https://www.phoenixcontact.com/us/products/3076039

Mechanical data	
Open side panel	Yes
Mechanical tests	
Mechanical strength	
Result	Test passed
Attachment on the carrier	
DIN rail/fixing support	NS 35
Test force setpoint	5 N
Result	Test passed
Test for conductor demand and alcalism	
Test for conductor damage and slackening	40 mm
Rotation speed Revolutions	10 rpm 135
Conductor cross section/weight	0.2 mm² / 0.2 kg
Conductor cross section/weight	6 mm ² / 1.4 kg
	10 mm² / 2 kg
Result	Test passed
rosuit	1001 passed
Aging	
Temperature cycles	192
	192 Test passed
Temperature cycles	
Temperature cycles Result	
Temperature cycles Result Needle-flame test	Test passed
Temperature cycles Result Needle-flame test Time of exposure	Test passed 30 s
Temperature cycles Result Needle-flame test Time of exposure Result	Test passed 30 s
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise	Test passed 30 s Test passed
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ 6.12 (m/s²)²/Hz
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ 6.12 (m/s²)²/Hz 3.12g
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ 6.12 (m/s²)²/Hz 3.12g 5 h
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz $6.12 \text{ (m/s}^2)^2\text{/Hz}$ $3.12g$ 5 h X-, Y- and Z-axis
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz $6.12 \text{ (m/s}^2)^2\text{/Hz}$ $3.12g$ 5 h X-, Y- and Z-axis
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result Shocks	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ 6.12 (m/s²)²/Hz 3.12g 5 h X-, Y- and Z-axis Test passed
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result Shocks Specification	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz $6.12 \text{ (m/s}^2)^2$ /Hz $3.12g$ 5 h X-, Y- and Z-axis Test passed DIN EN 50155 (VDE 0115-200):2008-03
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result Shocks Specification Pulse shape	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2008-03 Service life test category 2, bogie-mounted f ₁ = 5 Hz to f ₂ = 250 Hz 6.12 (m/s²)²/Hz 3.12g 5 h X-, Y- and Z-axis Test passed DIN EN 50155 (VDE 0115-200):2008-03 Half-sine



3076039

https://www.phoenixcontact.com/us/products/3076039


Test directions	X-, Y- and Z-axis (pos. and neg.)
Result	Test passed
Ambient conditions	
Ambient temperature (operation)	-60 °C 110 °C (Operating temperature range incl. self-heating for max. short-term operating temperature, see RTI Elec.)
Ambient temperature (storage/transport)	-25 °C 60 °C (for a short time, not exceeding 24 h, -60 °C to +70 °C)
Ambient temperature (assembly)	-5 °C 70 °C
Permissible humidity (operation)	20 % 90 %
Permissible humidity (storage/transport)	30 % 70 %
ounting	
Mounting type	NS 35/7,5
	NS 35/15




3076039

https://www.phoenixcontact.com/us/products/3076039

Drawings







3076039

https://www.phoenixcontact.com/us/products/3076039

Approvals

To download certificates, visit the product detail page: https://www.phoenixcontact.com/us/products/3076039

CSA Approval ID: 13631				
	Nominal voltage U_N	Nominal current I _N	Cross section AWG	Cross section mm ²
Use group B				
	300 V	20 A	24 - 8	-
Use group D				
	300 V	10 A	24 - 8	-

ERC	EAC
LIIL	Approval ID: RU C-DE.A*30.B.01742

CULus Recognized Approval ID: E60425				
	Nominal voltage U _N	Nominal current I _N	Cross section AWG	Cross section mm ²
Use group B				
	300 V	20 A	24 - 8	-
PE connection	-	-	24 - 8	-
Use group D				
	300 V	10 A	24 - 8	-
PE connection	-	-	24 - 8	-

EHC	EAC
LIIL	Approval ID: RU C-DE.BL08.B.00534



3076039

https://www.phoenixcontact.com/us/products/3076039

Classifications

ECLASS

	ECLASS-11.0	27141125		
	ECLASS-12.0	27141125		
	ECLASS-13.0	27250110		
ETIM				
	ETIM 9.0	EC001329		
UN	UNSPSC			
	UNSPSC 21.0	39121400		



3076039

https://www.phoenixcontact.com/us/products/3076039

Environmental product compliance

EU RoHS

Fulfills EU RoHS substance requirements	Yes, No exemptions
China RoHS	
Environment friendly use period (EFUP)	EFUP-E
	No hazardous substances above the limits
EU REACH SVHC	
REACH candidate substance (CAS No.)	No substance above 0.1 wt%
EF3.0 Climate Change	
CO2e kg	0.201 kg CO2e

Phoenix Contact 2024 @ - all rights reserved https://www.phoenixcontact.com

Phoenix Contact USA 586 Fulling Mill Road Middletown, PA 17057, United States (+717) 944-1300 info@phoenixcon.com